



Ref: ASD52/8250/SSD508/R20/800A

12 June 2017

(Attn: Mr. Jason POON, Asst. Project Manager)

Dear Sirs,

Contract No. SS D508

Signature Project Scheme (Central & Western District) –  
Harbourfront Enhancement and Revitalisation at the Western Wholesale Food Market  
(Programme No. 453RO)

Material Submission (PT-203/ARCH/M-050A)

We refer to your captioned material submission dated 6 June 2017. On the basis of the information given, please note the following comments for your attention and action:-


Material : 1 hour fire-rated board with insulation for wall and ceiling  
Brand/ Manufacturer/ Supplier : WINS / WINS Consultants Ltd.  
Proposed location of application : Container toilets  
Comments : Approved subject to:-

1. The proposed material is used in compliance with the relevant section of General Specification for Building 2012 (G.S.) issued by ArchSD;
2. The instructions and application specification provided by the manufacturer should be followed;
3. Material Sample to be submitted;
4. Shop drawings including the proposed setting out of supporting frame, etc. to be submitted for review;
5. Test report and Fire Certificate certifying the proposed product is in compliance with BS476 Part 22:1987 on integrity and insulation to be provided before completion of the project.

A duly signed copy of the "Material Submission and Approval Form" and the material sample is returned herewith.

Please be reminded that the approval / comment on your submission is given for your reference only. It should not be construed to be any instruction or agreement for a variation work, and it shall not in any way be taken to relieve your obligation, responsibility and liability for proper coordination and installation of the works.

Yours faithfully,



(Claudia NG)

for Chief Architect/2  
Architectural Services Department

Encl.

c.c. PQS  
PCOW

- Mr. Y. C. LEE  
- Mr. K. C. MAK (all w/e)

File via A/210

~~EA~~/CN/cn

